

## Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

### I. Petroleum Products

Date Reported*	Date Discovered	Discharger	Location	Problem	Action
1/6/04	1/6/2004	HADLEY AUTO TRANSPORT	4500 ETIWANDA AVENUE, MIRA LOMA	UNDERGROUND STORAGE TANK LEAK: CONTAMINATED SOIL	SITE WORKPLAN SUBMITTED
1/6/04	12/2/2003	COUNTY OF ORANGE PFRD	1750 DOUGLAS ROAD S., ANAHEIM	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	LEAK BEING CONFIRMED
1/7/04	12/9/2003	CHEVRON STATION #9-1660	3048 BRISTOL STREET, COSTA MESA	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	SITE WORKPLAN UNDERWAY
1/20/04	1/16/2004	FORMER USF BESTWAY INC.	10691 POPLAR AVENUE, FONTANA	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	POLLUTION CHARACTERIZATION
1/26/04	12/18/2003	ROBERTSON'S READY MIX	9010 SANTA ANA CANYON ROAD, E., ANAHEIM	UNDERGROUND STORAGE TANK LEAK: CONTAMINATED SOIL	LEAK BEING CONFIRMED
2/9/04	1/29/2004	SHELL CENTRAL	3504 CENTRAL AVENUE, RIVERSIDE	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED
2/9/04	2/9/2004	SHELL PERRIS BLVD.	15980 PERRIS BLVD., MORENO VALLEY	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED
2/11/04	12/16/2003	CARDLOCK FUEL SYSTEM, INC.	1825 COLLINS, ORANGE	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	LEAK BEING CONFIRMED
3/1/04	1/21/2004	YOUR NEIGHBORHOOD GAS STATION	1045 EL CAMINO DRIVE, COSTA MESA	UNDERGROUND STORAGE TANK LEAK: UNLEAD GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED
3/10/04	3/2/2004	DEER CREEK CAR WASH	10340 FOOTHILL BOULEVARD, RANCHO CUCAMONGA	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	POLLUTION CHARACTERIZATION
3/10/04	10/6/2003	7/11 # 25806	17305 ARROW BOULEVARD, FONTANA	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	POLLUTION CHARACTERIZATION
3/12/04	2/10/2004	CITY OF CYPRESS CORPORATION YARD	5285 CYPRESS STREET, CYPRESS	UNDERGROUND STORAGE TANK LEAK: UNLEAD GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED

## I. Petroleum Products

<b>Date Reported*</b>	<b>Date Discovered</b>	<b>Discharger</b>	<b>Location</b>	<b>Problem</b>	<b>Action</b>
3/15/04	3/15/2004	RIVERBEND CAR WASH	22280 LA PALMA AVENUE, EAST, YORBA LINDA	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED
3/22/04	3/2/2004	CYPRESS GOLF CLUB	4921 KATELLA AVENUE, CYPRESS	UNDERGROUND STORAGE TANK LEAK: UNLEAD GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED
3/25/04	3/16/2004	FERGUSON PROPERTY	424 NORTH MAIN STREET, LAKE ELSINORE	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	SITE WORKPLAN UNDERWAY
3/31/04	2/6/2004	FOREST LAWN MEMORIAL PARK	4471 LINCOLN AVENUE, CYPRESS	UNDERGROUND STORAGE TANK LEAK: UNLEAD GASOLINE CONTAMINATED SOIL	LEAK BEING CONFIRMED
4/6/04	3/10/2004	NEWPORT AUTO CENTER	445 EAST COAST HWY., NEWPORT BEACH	UNDERGROUND STORAGE TANK LEAK: CONTAMINATED SOIL	LEAK BEING CONFIRMED

\*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger. This report may not contain an accurate listing of all the new cases due to the ongoing reconciliation between the Geotracker/GEIMS, DOD, and Local Agency databases.\*

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/17/04	2/8/04	38665	Private Property Owner	1555 Mesa Verde East @ Golf Course Drive, Costa Mesa, Orange County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a private lateral due to a grease blockage. 600 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain and to Greenville Banning Channel. The blockage was removed, the affected area was cleaned up and disinfected by Costa Mesa Water District.
2/17/04	2/17/04	38646	City of Huntington Beach	6002 Bolsa Ave., Huntington Beach, Orange County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a private property's lateral due to unknown reason. Unknown amount of the spill was contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into the local storm drain. The blockage was cleared, the affected area was cleaned up and disinfected by private contractor with assistance of Huntington Beach staff.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/17/04	2/17/04	38645	City of Beaumont	8th & Veile Ave., Beaumont, Riverside County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to a grease blockage. All 500 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was removed, the affected area was cleaned up and disinfected by the City of Beaumont.
2/21/04	2/21/04	38603	City of Colton	1147 Bronze Star Court, Colton, Riverside County	SSO	1,200	An estimated 1,200 gallons of sewage overflowed from a manhole due to a lift station failure. All 1,200 gallons of the spill discharged into the local storm drain. The lift station was repaired, the contaminated area was cleaned up and disinfected by the City of Colton staff.

# SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

## SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
2/22/04	2/22/04	38647	Vandals	22205 Shady Rim Circle, Lake Forest, Orange County	SSO	43,875	An estimated 43,875 gallons of sewage overflowed from a manhole due to hemispherical shape (12" in diameter and 6" Wide) rock dropped into the manhole by vandals. 9,000 gallons of the sewage were contained, recovered, and returned to the operational sewer system. The rest of the spill discharged to Serrano Creek and flowed to San Diego Creek and to Upper Newport Bay. The rock was removed, the sewer line was repaired, the effected area was cleaned up and disinfected by IRWD's staff.
3/3/04	3/3/04	38623	Private Property Owner	1460 W. Lambert, La Habra, Orange County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a private manhole due to grease blockage. 500 gallons of the spill contained, recovered, and returned to the operational sewer system. 1,000 gallons of the spill discharged into the local storm drain and flowed to Cayote Creek and to San Gabriel River. The grease blockage was removed, the affected area was cleaned up and disinfected by a private contractor with assistance of the City of La Habra.

# SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

## SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/3/04	3/3/04	38644	City of Newport Beach	Dove & Birch Ave., Newport Beach, Orange County	SSO	650	An estimated 650 gallons of the sewage overflowed from a manhole due to grease blockage. 250 gallons of the spill were contained, recovered, and returned into the operational sewer system while the rest of the spill discharged to the local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of the Newport Beach.
3/4/04	3/4/04	38624	City of Placentia	100 Block of Essex Circle, Placentia, Orange County	SSO	2,550	An estimated 2,550 gallons of sewage overflowed from a manhole due to grease blockage. 750 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain and to catch basin. The grease blockage was removed, the affected area was cleaned up and disinfected by the City of Placentia.

## SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

### SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/7/04	3/7/04	38583	Private Property Owner	8282 E. Oak Ridge Circle, Anaheim, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private lateral due to tree roots. 200 gallons of the spill contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The tree roots was removed and the private lateral was cleared by a private contractor with assistance of the City of Anaheim staff.
3/16/04	3/16/04	38666	CMVWD	9000- 9th Street, Rancho Cucamonga	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to tree roots blockage. All 500 gallons of the spill were contained, recovered, and returned to the operational sewer system. The tree roots was removed, the affected area was cleaned up and disinfected by CVWD's staff.

# SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

## SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/17/04	3/17/04	38664	Private Property Owner	6518 E. Camino Vista, Anaheim, Orange County	SSO	1,030	An estimated 1,030 gallons of sewage overflowed from a private manhole due to tree roots. 70 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into the catch basin at intersection of Vista & Camino Grande. The tree roots was removed, the affected area was cleaned up and disinfected by a private contractor with assistance of IRWD's staff.
3/17/04	3/18/04	38643	City of Riverside	5956 Montgomery Street, Riverside, Riverside County	SSO	700	An estimated 700 gallons of sewage overflowed from a manhole due to debris dropped into a manhole by vandals. 210 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into the local storm drain. The debris was removed from the manhole, the affected area was cleaned up and disinfected by the City of Riverside staff.



# SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

## SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/19/04	3/19/04	38663	IRWD	University Drive & Campus Drive, Irvine, Orange County	SSO	1,365	An estimated 1,365 gallons of sewage overflowed from a sewer line break. All 1,365 gallons of the spill were contained, recovered, and returned to the operational sewer system. The sewer line was repaired, the affected area was cleaned up and disinfected by IRWD's staff.
3/19/04	3/19/04	38704	City of Anaheim	310 S. Mohler Drive, Anaheim, Orange County	SSO	800	An estimated 800 gallons of sewage leaked from a damaged sewer line caused by electrical contractor. 40 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain and to the Santa Ana River. The broken line was repaired, the affected area was cleaned up and disinfected by the City of Anaheim staff.

# SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

## SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
3/27/04	3/27/04	38668	Huntington Beach	417 Yorktown, Huntington Beach, Orange County	SSO	1,160	An estimated 1,160 gallons of sewage overflowed from a manhole due to a grease blockage. 780 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into County Channel Pump Station where it diverted to a sewer system. The blockage was removed, the affected area was cleaned up and disinfected by the City of Huntington Beach.
3/31/04	3/30/04	38683	City of Riverside	3742 Park Sierra Drive, Riverside, Riverside County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to grease blockage. 100 gallons of the spill contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Riverside staff.

# SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

## SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
4/6/04	4/6/04	38723	Private Property Owner	1599 Superior Avenue, Costa Mesa, Orange County	SSO	3,000	An estimated 3,000 gallons of sewage overflowed from a five unit housing complex's lateral. All 3,000 gallons of the spill discharged into a local storm drain and flowed to the Newport Bay. The water between Harbor Tower Marina near West Coast Highway and Newport Boulevard, down to Riverside Avenue, is closed to swimming and diving until further notice. The blockage was removed, the affected area was cleaned up and disinfected by private properties contractor with assistance of CMSD's staff.
4/8/04	4/8/04	38703	City of Ontario	5th at Helen, Ontario, San Bernardino County	SSO	1,500	An estimated 1,500 gallons of sewage overflowed from a manhole due to grease blockage. All 1,500 gallons of the spill discharged into the local storm drain. The blockage was removed, the affected area was cleaned up and disinfected by the City of Ontario staff.

Row(s) 1 - 20